



## CORPORATION STOP APPLICATION DATA

### Application

The use of a corporation stop is required when the process water pipe cannot be drained at the diffuser to allow for maintenance. With a corporation stop, the diffuser can be removed while the process water pipe remains full and pressurized.

Maximum pressure rating for standard corporation stops is 125 PSI.

Corporation stops are available with a variety of threaded and hose inlet connections. See Figures 1, 2, 3, and 4 for recommended installation configurations.

### Solution Tube Penetration Length

A corporation stop allows the injected chemical to enter the process water line away from the edge of the pipe. This facilitates more rapid and complete mixing of the injected chemical solution. See Figure 5. It is recommended that the solution tube does not penetrate further than  $\frac{1}{3}$  of the process water line diameter. Please specify solution tube penetration length when ordering.

### Installations

Any installation of a corporation stop must allow for sufficient clearance to remove the diffuser by pulling it toward the ejector after the nut has been loosened.

**Rigid Pipe:** See Figures 2 and 4. When using rigid pipe a shutoff valve and an elbow must be installed with a union after the turn. The shutoff valve will allow isolation of the section of pipe during removal. The union will allow withdrawal of the diffuser.

**Hose:** See Figures 1 and 3. Sufficient clearance must be available to remove the diffuser by pulling it toward the ejector after the nut has been loosened.

**Safety Chain:** The purpose of the safety chain is to prevent the solution diffuser from blowing out due to high pressure in the process water line after the nut has been loosened on the corporation stop. Take care when loosening the nut as the solution diffuser may be forced outward at high velocity. However, the safety chain will prevent the solution diffuser from coming completely out of the corporation stop. When the safety chain is taut, the corporation stop valve is to be closed. After this valve has been closed, the chain should be detached to allow removal of the solution diffuser assembly.

